

# GW-001 Series Range Omega Link Etherne

Long Range Omega Link Ethernet Gateway





omega.com info@omega.com

### **Omega Engineering**, Inc:

Omega Engineering, Inc.

800 Connecticut Ave. Suite 5N01, Norwalk, CT 06854 Toll-Free: 1-800-826-6342 (USA & Canada only) Customer Service: 1-800-622-2378 (USA & Canada only)

Engineering Service: 1-800-872-9436 (USA & Canada only)

Fax: (203) 359-7700

Tel: (203) 359-1660

e-mail: info@omega.com

The information contained in this document is believed to be correct, but OMEGA accepts no liability for any errors it contains and reserves the right to alter specifications without notice.

## **Table of Contents**

Та	able of	Contents	3
1	Not	es, Cautions, and Warnings	5
2	Intro	oduction	6
3		-001 Hardware Overview	
3	3.1	-001 Hardware Overview Smart Sensor Pairing	
	3.2	USB 2.0 Connectors	
	3.3	Serial Data and Alarm Connector	
	<b>3.3</b> .1		
	3.4	RJ45 Port	
4		ega Link Gateway First-Time Setup	
4	4.1	Registering your Gateway to Omega Link Cloud	
_			
5	First	t-Time Gateway Internal UI Access Connected Devices – Main Interface	
	<b>5.1</b> .1		
	5.1.1		
	5.1.2	•	
	5.1.2		
	5.1.4 5.2	GW-001 Settings	
	<b>5.2</b> .1		
	5.2.2	<b>.</b>	
	5.2.2	, 5	
	5.2.4		
6	6.1.1		18
7		v to Pair a Sensing Device to an Omega Link Gateway	
		Wireless Pairing	
	7.1.1	5	
	7.2	Wired Pairing	. 20
8	Nav	igating Omega Link Cloud	. 21
	8.1	Devices	. 21
	8.1.1	L Gateway Details	21
	8.1.2	2 Management	22
	8.1.3	3 Sensor Analytics	24
	8.2	Historian	. 27
	8.2.1	l How to Generate a Historical Data Report	27
	8.3	System Settings	. 31
	8.3.1	Profile	31
	8.3.2	2 Units	32
	8.3.3	3 Users	32
	8.3.4	4 Subscription	33
	8.3.5	5 Contact Us	33
	8.4	How to Remove a Paired Smart Sensor from a Gateway	. 34
	8.4.1	L How to Move a Paired Smart Sensor to a Different Gateway	34
9	Cert	ification	35

10	General Public License Statement	5
11	Specifications	6



### **1** Notes, Cautions, and Warnings

If the equipment is used in a manner not specified in this manual, the protection by the equipment may be impaired.

Do not operate the equipment in flammable or explosive environments.

It is important to read and follow all precautions and instructions in this manual before operating or commissioning this device as it contains important information relating to safety and EMC. Failure to follow all the safety precautions may result in injury and/or damage to the equipment.

The following labels identify information that is especially important to note:

Note 🖙

Note: Provides information that is important to successfully set up and use the Omega Link Gateway.



Caution or Warning: Informs about the risk of electrical shock.

**Caution, Warning, or Important:** Informs of circumstances that can affect the functionality of the instruments and must refer to accompanying documents.



## 2 Introduction

The Omega Link Ethernet Gateway (GW-001 Series) is a high-performance gateway that allows for seamless, wireless, connection to up to 100 long-range Omega Link Smart Sensor Devices. The Ethernet-enabled RJ45 connectivity ensures a direct connection to the Omega Link Cloud or to a local-area enterprise network. The local built-in web server is also accessible through the RJ45 port. The different GW-001 series models support multiple device connection types including Modbus TCP/RTU RS232/RS485 and USB ports to enable local smart probe connections.

Omega Link Cloud and OEG subscription tiers can be purchased on the Omega website.



Important: Users who will only be connecting to a local-area, enterprise ecosystem with Omega Enterprise Gateway (OEG) do not need to create an Omega Link Cloud account to use the Omega Link Gateway in Enterprise Mode.

Refer to the following LED Status Indicator table to identify the different Gateway behaviors and statuses.

LED Color	Status Description
Amber/Orange (solid)	Gateway is powered on; no network connection
Green (blinking repeatedly)	Gateway is in Pairing Mode or Firmware Upgrade was successful
Amber/Orange (blinking + reboot)	Gateway firmware automatic update
Red (blinking)	Gateway is powering on or Firmware Upgrade in progress
Amber/Orange (blinking 3 times and a 3 second pause)	Enterprise Mode enabled
Green (solid)	IP Address successfully obtained or network connection successful
No Light	Unit is off or in Sleep Mode

Â

Important: Do not power on the Omega Link Gateway or Omega Link Smart Sensor before the Gateway registration is complete for Omega Link Cloud connections. Refer to section 4.1 Registering your Gateway to Omega Link Cloud for more information.



### 3 GW-001 Hardware Overview

GW-001 series gateways offer the following connector and pairing options to pair sensing devices to the Gateway (connector options vary per model):

- Smart Sensor one-button pairing
- USB 2.0 Connector
- Serial Data and Alarm 5-pin screw terminal
- RJ45 connector for local network and Internet access

#### 3.1 Smart Sensor Pairing

Pairing an Omega Link Smart Sensor to your Omega Link Gateway is made easy with one-button pairing. Simply press the pairing button on your gateway and press the pairing button on your Smart Sensor to connect the two. Your Smart Sensor will now be visible on your Omega Link Cloud or OEG web interface.




Figure 1: Smart Sensor to Gateway pairing button

#### 3.2 USB 2.0 Connectors

The USB 2.0 connector is used to connect Omega Link Smart Probes with an Omega Link IF-001 Smart Interface Cable directly to your gateway.

#### 3.3 Serial Data and Alarm Connector

The 5-pin terminal can accept RS232 or RS485 inputs from authorized Omega accessories and devices such as OM240, CN616A, and DP612. The 5-pin screw connector on the gateway is labeled as follows:

Pin	Description
Pin 1	TX (D+)
Pin 2	RX (D-)
Pin 3	GND
Pin 4	Alarm (N/O)
Pin 5	Alarm (N/O)




Figure 2: GW-001 Series input connectors (varies by model)

Contact Omega or visit our website to see other compatible devices.

#### 3.3.1 Alarm Relay Wiring

3.4

The 5-pin screw terminal can be used to connect a peripheral alarm relay that will be triggered if the gateway loses network connection to the Omega Link Cloud or OEG.

Note: This alarm will not detect a cabling or wiring issue. The alarm will sound if the Gateway cannot reach the Omega Link Cloud or OEG network.

## 

#### Figure 3: Alarm relay wiring diagram

RJ45 Port An RJ45 port is provided for local-network and Internet access, can be used for ModBus TCP devices, and some models offer a Power over Ethernet feature.






## 4 Omega Link Gateway First-Time Setup

Refer to the LED color status table below and follow these instructions to power on the GW-001 unit:

LED Color	Status Description
Amber/Orange (solid)	Gateway is powered on; no network connection
Green (blinking repeatedly)	Gateway is in Pairing Mode or Firmware Upgrade was successful
Amber/Orange (blinking + Reboot)	Gateway firmware automatic update
Red (blinking)	Gateway is powering on or Firmware Upgrade in progress
Amber/Orange (blinking 3 times and a 3 second pause)	Enterprise Mode enabled
Green (solid)	IP Address successfully obtained or network connection successful
No Light	Unit is off or in Sleep Mode

Important: For setups that will use Omega Link Cloud, do not power on the Omega Link Gateway or Omega Link Smart Sensor before the Gateway has been registered to an Omega Link Cloud account. Refer to section 4.1 Registering your Gateway to Omega Link Cloud for more information.

- **Step 1:** Connect the antenna included with the gateway to the side of the device housing.
- **Step 2:** Connect the DC 12 V adapter to the back of the gateway.
- Step 3: Connect an RJ45 Ethernet cable to the port labeled Ethernet 1 on the gateway.
- Step 4: Connect the other end of the Ethernet cable to a DHCPenabled router with Internet access for first-time setup.





Important: The GW-001 must be connected to a router with internet access when setup for the first time to ensure the latest firmware is automatically downloaded onto the device.

Step 5: Turn the power switch on the gateway to the ON position.

**Step 6:** The LED light on the Pairing Button will blink red to indicate that the device is booting up and updating firmware.

Once the gateway is connected to the Internet, the Omega Link Gateway unit will automatically download the latest firmware available and the LED status indicator will stay a solid green when the update is complete.



#### 4.1 Registering your Gateway to Omega Link Cloud



Note: Users who will not be creating an Omega Link Cloud account and will be connecting to Omega Enterprise Gateway (OEG) in a noninternet environment should refer to section 5 First-Time **Gateway Internal UI Access** 

To register your Omega Link Gateway with Omega Link Cloud, you must first create and register an Omega Link Cloud account. Using any device with a web browser, complete the following steps:

Step 1: Open your browser to *cloud.omega.com*.

Step 2: Click Sign Up and complete the registration process.

Once the user credentials are verified, the user can sign in and will be presented with the Omega Link Cloud homepage.

Step 3: From the cloud homepage, click Add Gateway.

🔗 Omega Link
Email
Password
Login
Forgot Password? <b>or</b> Sign Up
Omega Engineering Inc.
Privacy Policy   Terms of use

#### Figure 5: Omega Link Cloud login



Figure 6: Omega Link Cloud Add Gateway button

- Step 4: Type in the Gateway ID (GID) from the label on your gateway.
- Step 5: Type in the Registration ID (RID) from the label on your gateway and click Register.

Note 🖙 Note: The

Important: The label containing your Gateway ID and Register ID is located on the bottom of the gateway unit.

**Step 6:** Once you have successfully registered your gateway, an

icon will disappear once the registered gateway is powered on.



Figure 7: Sample Omega Link Gateway label

icon will appear next to your registered device.

## 5 First-Time Gateway Internal UI Access

Important: A firmware update for the GW-001 is required to access the internal UI as listed below. The latest firmware is automatically installed when the GW-001 is connected directly to a router with Internet access.

All Omega Link Gateway models contain an internal user interface (UI) that is used to manually upgrade firmware, add wired sensing devices to the gateway, and add other external accessories and peripherals. When accessing the gateway UI for the first time, with the Gateway still plugged in to the DHCP-enabled router with Internet access, follow the steps below:

Step 1: Using a PC or a device with a web browser on the same network as the connected GW-001, type the following URL: <u>http://omegaiotgatewayXXXX.local</u>

(Where the XXXX are the last 4 digits of the GW-001 MAC address printed on the rear label).

Important: If the user is unable to access the Gateway UI using the DHCP-router method, the Bonjour Service may need to be installed. The service can be downloaded from the following URL: http://omegaupdates.azurewebsites.net/software/bonjour

**Step 2:** From the gateway UI login screen, enter the password on the rear label of the unit. When entered successfully, the user will be prompted to create a new password.

Once the user has accessed the UI for the first time, they may leave the network settings as DHCP, or they may choose a Static IP under the Network Settings menu. Additionally, after the first-time setup, the user may choose to enable Enterprise Mode to pair the GW-001 to an Omega Enterprise Gateway (OEG) account. Refer to the section titled **6 Registering your Gateway to OEG (Enterprise Mode)** to learn more about how to enable Enterprise Mode and to pair a GW-001 to OEG, or continue below for an explanation of the different menus available in the GW-001 internal UI.

#### 5.1 Connected Devices – Main Interface

CE OMEGA	CONNECTED DEVICES SETTINGS -
Model: GW-001-2 Main FW: 200.0.11 HW: A1 RF FW: 5.20.0.00 R	egion: NA
Show 10 - entries	Add Search
SS-001-3 <b>m</b> 0012480021529C79	
Firmware RF Firmware 4.0.255.255 1.1.3.2	
Show 1 to 10 of 1 entries	1

#### Figure 8: Gateway web UI main page - Connected Devices

The **Connected Devices** tab is the default page that appears when a user has successfully signed in to the internal gateway UI. From here, users can add wired devices to the gateway to have them appear in your Omega Link Cloud or OEG account. Wirelessly paired devices will appear here as well. To pair a wired device to your gateway from the

internal gateway web UI, begin by clicking the information on how to pair a wireless sensing device such as an Omega Link Smart Probe or Smart Sensor, refer to section: **7 How to Pair a Sensing Device to an Omega Link Gateway**.



#### 5.1.1 Controller 1. Specify Product When adding a Product Family Product Model Name controller, ensure the Controller v CN616A ~ Name **Product Family** dropdown is set to 2. Specify Connection Parameters **Controller**, and choose Interface your controller type ~ RS232 from the Product Model Device ID dropdown. You can then 1 set the communication Baud Data bits Stop bits parameters for your 9600 ~ 8 1 ~ device including the interface type, baud Parity rate, data bits, stop bits, ~ None parity, device ID, and 3. Specify How Often reading interval. Reading Interval (seconds) 20

Figure 9: Add Device – Controller Setup

#### 5.1.1.1 Omega Platinum

Omega Platinum controllers being added to the GW-001 require users to identify the IP address and Port number of the Controller device.

. Specify Product Product Family	Product Model	Name	
Controller	✓ Platinum	✓ Name	
Specify Connection P	arameters		
. Specify Connection P	arameters		
Specify Connection Politics	IP Address	Port	
		Port 502	
Interface	IP Address		

Figure 10: Platinum series controller Add Device interface



### 5.1.2 **DAQ**

To add a DAQ device, select it from the **Product Family** dropdown and select your **Product Model** from the dropdown. You can then set the communication parameters for your device including interface type, IP address, port number, device ID, and reading interval.

Product Family		Product Model		Name	
DAQ	~	OM240	~	Name	
2. Specify Connectic	on Parameters	IP Address		Port	
ТСР	~	0.0.0.0		502	
Device ID 1					
3. Specify How Ofte	n				

#### Figure 11: DAQ series Add Device interface

Omega DAQ devices require users to know the IP address of their controller device. An IP scanner software can be used to identify the DAQ IP address.

#### 5.1.3 Meter

To add a Meter device, select it from the **Product Family** dropdown and select your **Product Model** from the dropdown. You can then set the communication parameters for your device including the interface type, baud rate, data bits, stop bits, parity, device ID, and reading interval.

Product Family		Product Model		Name	
Meter	~	DP612A	~	Name	
2. Specify Connection	Parameters				
Interface					
RS232	~				
Device ID					
1					
Baud		Data bits		Stop bits	
9600	~	8		1	
Parity					
None	~				
3. Specify How Often					
s. specily now Olten					

Figure 12: Meter Add Device interface



#### 5.1.4 **Probe**

To add a Smart Probe, select it from the **Product Family** dropdown and select your **Product Model** from the dropdown. You can then set the communication parameters for your device including the interface type, device ID, and reading interval.

Product Family		Product Model		Name
Probe	~	SPXXX	~	Name
Interface USB	~			
	~			
Device ID				
1				
1				
I				
Specify How Often				
B. Specify How Often Reading Interval (seco	onds)			

Figure 13: Omega Link Smart Probe Add Device interface



#### 5.2 GW-001 Settings

Click the settings tab to view log data, update gateway firmware versions, change security passwords, and view current network settings.

#### 5.2.1 Network Settings

To view and change the Network settings, select it from the **Settings** dropdown at the top right of the webpage UI. From here, you can change your gateway device name and change your **IP Assignment** between DHCP and Static IP.

Network Settings				
Device Name:	GW-001-3			
IP Assignment:	DHCP ~			
IP Address:	192.168.100.104			
Subnet Mask:	255.255.255.0			
Default Gateway:	192.168.100.1			
Primary DNS:	4.2.2.2			
Secondary DNS:	8.8.8.8			
Update				

Figure 14: Gateway UI Network Settings

#### 5.2.2 Security Settings

To manage the password required to access your gateway web UI, select the **Security** option from the **Settings** dropdown at the top right of the webpage UI. From here, users can turn off the cloud registration to enable Enterprise Mode. For more information, refer to section **6 Registering your Gateway to OEG (Enterprise Mode)**.

🔒 Secur	ity Settings
Change Adm	nin Password
Existing Password:	
New Password:	
Confirm Password:	
Use Secure Web:	🔾 on 🖲 off
Turn off Cloud Registration:	0

Figure 15: Gateway UI Password and Security Settings

#### 5.2.3 System Settings

To update your gateway firmware version, factory reset your device, or soft reboot your device, select **System** from the **Settings** dropdown at the top right of the webpage UI. When updating the firmware version, click **Check Online** to download the latest firmware version available for your gateway. Then, click

the **C** icon to find the file on your computer. Finally, click **Upload** to get the latest firmware on your gateway.




Figure 16: Gateway UI System Setting, Firmware update, and Factory Reset interface

Warning: Clicking the Factory Reset button erases all saved data and configurations. Your gateway will be changed back to the default, out-of-the-box settings.

#### 5.2.3.1 How to Update the Firmware on an Omega Link Gateway

Once in the **System Settings**, the user may click the magnifying glass icon accompanying the **Upload Firmware** box to open the **File Explorer**. Select the new firmware file and click **Open**. Click **Upload** to confirm the firmware upgrade. A red LED on the gateway will indicate that the upgrade is in process.

Once the update process is complete, log out and log back in. The new firmware version will appear on the main page of the internal gateway interface.

#### 5.2.4 **Log**

Select Log from the System dropdown to view a timestamped report of the events that have occurred with your gateway.

Cog Log				
			Page 1 /	
Time	Level	Log		
4/12/2021, 11:36:32 PM	Info	connected to iothub		
4/12/2021, 11:36:32 PM	Info	connected to the cloud		
4/12/2021, 11:36:28 PM	Info	provisioned gateway successfully		
4/12/2021, 11:36:12 PM	Info	connected to the Internet		
4/12/2021, 11:35:46 PM	Info	started radio manager		

Figure 17: Gateway UI Log table



### 6 Registering your Gateway to OEG (Enterprise Mode)

A Omega Link Gateway can be added to Omega Enterprise Gateway (OEG) in a non-internet environment by enabling **Enterprise Mode** on the Gateway unit. To add an Omega Link Gateway to OEG, the **Cloud Registration** option needs to be disabled by accessing the **System Settings** in the Gateway web UI. Once disabled, the gateway will be in **Enterprise Mode**.

Important: If the OEG License being used has not been activated, an internet connection will be needed for a onetime license activation before proceeding. Adding an Omega Link Gateway as a Device to OEG is only available on non-trial licenses of OEG.

Step 1: Navigate to the Security Settings in the Gateway UI.

Step 2: Click the Turn Off Cloud Registration checkbox to disable the feature and set the GW-001 to Enterprise Mode.

Secur	rity Settings
Change Adn	nin Password
Existing Password:	
New Password:	
Confirm Password:	
Use Secure Web:	🔾 on 💿 off
Turn off Cloud Registration:	
Upd	date

Figure 18: Gateway UI Security Settings – Turn off Cloud Registration

- Step 3: Click the Update button to save the setting change. The gateway LED will flash orange 3 times indicating the device is in Enterprise Mode.
- Note: The GW-001 may be configured to use a Static IP rather than the default DHCP. If these settings are changed, the PC or local-area network router must be on the same local-area network as the Static IP address assigned to the GW-001 unit.

If the GW-001 will be moved and connected to a local-area network, it should be moved now and connected directly to a DHCP-enabled, local-area network router or local-area network PC.

Step 4: Launch and log in to your Omega Enterprise Gateway account.



Step 5: Click the ticon or Add Devices. Then select GW-001-Series Gateway from the Product Family dropdown and GW-XXX-X from the Product Model dropdown.

1. Specify Product			
Product Family	Product Model	Name	
GW-001-Series Gateway	- GWAXXX-X	Name	

Figure 19: OEG interface Add Device menu – Omega Link GW-XXX-X

Step 6: Input the IP Address of the connected Omega Link Gateway as it appears in your local-area network.

2. Specify Connection	Parameters		
Interface	IP Address	TCP Port	
(CP)			
Device ID ( For Modbo	us or RS485 Daisy Chain, please ensu	re ID matches device address)	

Figure 20: OEG interface Add Device menu – Connection Parameters

- Important: If the DHCP-enabled GW-001 unit has been disconnected and moved to a separate DHCP-enabled, localarea network router or PC, the user must log back into the gateway internal UI to identify the new IP Address that the unit has been assigned under the local-area network.
  - Step 7: Click Advanced to reveal the text field for Username and Password. The Username will automatically populate to "admin." Input the password required to access the gateway internal UI in the Password textbox.

Advanced		
4. Specify credential. It is	s not required for most omega produ	icts.
User Name	Password	
000		Secure Connection
		Add Cancel

Figure 21: OEG Interface Add Device menu – Gateway Username and Password input

Step 8: Click Add to finalize your configuration.



All devices connected to the Omega Link Gateway will appear, including those that are offline. The readings from offline units will display NaN. For more information on how to navigate OEG, refer to the OEG Software User's Manual.

Note: The maximum reading interval is 120 seconds for Omega Link Gateway. After switching to Enterprise Mode from Cloud Mode, the Omega Link Gateway device should be manually powered off and on again. Omega Enterprise Gateway should also be restarted from the Windows OS Services application. In the future, if users will be using the Omega Link Cloud service, they must navigate to the Gateway web UI again to uncheck the Turn off Cloud Registration box.

#### 6.1.1 Configuring Sensing Devices after Pairing with OEG

If a sensing device paired wirelessly or wired directly to the Omega Link Gateway has been configured or modified after the Omega Link Gateway has been added to OEG, the user must reboot the Omega Link Gateway and restart the OEG software to sync with the configuration made to the connected device.



### 7 How to Pair a Sensing Device to an Omega Link Gateway

Refer to either the Wireless Pairing or Wired Pairing instructions as applicable.

#### 7.1 Wireless Pairing

Pairing your wireless Smart Interface (IF-006) or Smart Sensor is made easy with a one-button pairing system between the IF-006 or Smart Sensor and the Omega Link Gateway.

Important: The pairing instructions for the SS-001-RUG differ from the standard wireless pairing procedure. Refer to section **7.1.1 SS-001-RUG Pairing** to pair an SS-001-RUG to your Omega Link Gateway.

- **Step 1:** Push the pairing button once on your Smart Sensor or IF-006 device. The LED Status Indicator will blink green indicating it is in Pairing Mode.
- **Step 2:** Quickly push the pairing button on the Omega Link Gateway. The LED on the Gateway will blink green indicating the Gateway is in Pairing Mode.

When the IF-006 or Smart Sensor has been successfully paired to the Omega Link Gateway, the LED will stop blinking on both devices.

#### 7.1.1 SS-001-RUG Pairing

To pair an SS-001-RUG sensor to an Omega Link Gateway, follow the instructions below:

- **Step 1:** Locate the small pinhole on the underside of the SS-001-RUG unit and insert a paperclip to press the button once. The LED Status Indicator at the top of the unit will blink green once when successfully completed.
- **Step 2:** Quickly push the pairing button on the Omega Link Gateway. The LED on the Gateway will blink green indicating the Gateway is in Pairing Mode.

When the SS-001-RUG has successfully been paired to the Gateway, the LED status indicator will briefly flash orange before flashing green one more time.



Note: Holding the pinhole button on the underside of the unit for longer than 5 seconds will reset the sensor to its factory default settings.



#### 7.2 Wired Pairing

Wired Smart Probes connected directly to an Omega Link Gateway with an IF-001 cable will need to add the device to the Gateway Internal User Interface.

The **Connected Devices** tab is the default page set once you are signed in to the internal gateway UI. From here, you can add devices to your gateway to have them appear in your Omega Link Cloud account.

CE OMEGA	and a start	CONNECTED DEVICES SETTINGS
Model: GW-001-2 Main FW: 200.0	.11 HW: A1 RF FW: 5.20.0.00 Regio	on: NA
Show 10 - entries		Add Search
SS-001-3 0012480021529C79	<b>m</b>	
Firmware RF Firmware 4.0.255.255 1.1.3.2		
Show 1 to 10 of 1 entries		1

Figure 22: Gateway Internal User Interface

To add a device to your gateway from the internal gateway web UI, begin by clicking the button at the top right of the web page. Refer to section **5.1 Connected Devices – Main Interface** for more information.



### 8 Navigating Omega Link Cloud

The Omega Link Cloud is the bridge between Omega Link Smart Sensing devices and getting your data when you need it on any device with a web browser. The Omega Link Cloud delivers state and status monitoring, data logging, visualization, and analytics. Accounts can be created and accessed by visiting: <u>http://cloud.omega.com</u>

Once you have access to your account and have completed your initial device pairing, you will be presented with your connected devices on the Omega Link Cloud interface.

#### 8.1 Devices

After signing in, the **Devices** tab immediately presents the readings of all registered Omega Link Gateways and their connected sensing devices. From here, you may access your gateway details, add additional gateways to your cloud account, monitor device health, and access specific sensor analytics.



Figure 23: Omega Link Cloud main interface - Devices

#### 8.1.1 Gateway Details

To view your gateway details or change the name of your

device, click the icon associated with the gateway you wish to view. From here, you will be able to change your gateway name and view your gateway ID, firmware version, model number, initial boot-up date and time, hardware type, manufacturer, and last recorded device heartbeat.

Gateway Name		
Test Gateway		
Firmware	Hardware	
1.0.13	A1	
Model	Manufacturer	
GW-001-3	Omega Engineering Inc.	
Boot Up	Last Heart Beat	
4/12/2021, 11:35:25 PM	4/15/2021, 5:31:37 PM	

Figure 24: Omega Link Cloud registered gateway details



#### 8.1.2 Management

Clicking the management icon allows you to create customizable groups of gateways, assign gateways to admins, and assign alarm notifications to other users.

#### 8.1.2.1 User and Device Assignment

To assign users to devices, click the Groups Groups icon, and click **Add Group**. After naming your group, you can click on these icons to add users and devices to your group.




Figure 25: Omega Link Cloud Users and Groups

#### **8.1.2.2** Creating a Device Group and Adding Devices To create a Device Group and add sensing devices to that group, follow these instructions:

🚱 Omega Link					
1 GATEWAYS 🏷	1	ø Sensors	1 SENSORS		2 ALARMS
⊟ fdg4560d1be Test Gateway	<b>* 8</b> 🖮	Add Gateway			
Show 24 Devices Sort By Device ID		Search x 1 > C	All Other Devices	s ===	
00124B0021B01182 ■ Test Gateway	•	Test Gateway ■ Test Gateway	28		
Temperature Humidity Door Contact 24-c 50.5 <sub>%RH</sub> Open		Temperature1 Temperature2 26.2°c 24.2°c			
Last reading: 9/30/2020, 3:31:38 PM		Last reading: 4/19/2021, 10:15:34 PM			

Figure 26: Omega Link Cloud devices homepage

- Step 1: On the Omega Link Cloud homepage, click on the management icon  $\ensuremath{\mathbbmm{B}}$  .
- Step 2: Click *Groups*, then click *Add Group* and create a name for your group. Click *Create* to finalize.

Г

	New Group
Management	Please enter a new group name:
Groups Gateway Alarms	Nest group under:
Figure 27: Device Management	Cancel
options	

Figure 28: New Group Interface

Note Note: The dropdown for **Nest Group Under** can be disregarded.



Step 3: Once your group is created, a pop-up window will appear with the title Manage Device Groups. Click

the **line** icon to add a user's email address and grant them access to the group. Click **OK** to finalize the changes.

Note 🖻

**Note:** Before adding a user to a group, the user must be granted access to the Omega Link Cloud account by completing the steps outlined in section **8.3.3.1 How to Add Users**.

.0	80		
	12 0	10 🖂 0	0 00

Figure 29: Device group management interface

**Step 4:** Once back on the *Manage Device Groups* window, click the icon to add sensing devices to your newly created group. Click **OK** to finalize the changes.

Show (	10 V entries		S	Search:
×	Device Name	Device ID	¢	Gateway Name
	Smart Sensor -1	00124B001E1E		Demo1Gateway
	SmartProbe-002	01014C3E2DE8		Demo1Gateway
Showin	g 1 to 2 of 2 entries			Previous Next

Figure 30: Assigning a device to a specific group

### 8.1.2.3 Assign Gateway to Admin (Admin Only)

To assign a gateway to an admin, click the Gateway Gateway icon. Enter the admin's email address and select the gateway that will be assigned to them. Click **Assign Gateway** to finalize.

<u>-</u>

### 8.1.2.4 Assign Alarm Notifications



To assign gateway alarms to other users, click the Alarms Alarms icon. Select your gateway, select the users to be assigned the alarm notifications, and click **Confirm Assign** to finalize.



#### 8.1.3 Sensor Analytics

To access the analytics of a specific sensor, click on the measurements of the sensor you wish to view.

#### 8.1.3.1 Measurements

The measurements tab displays graphs of the readings recorded by your sensor. It allows users to change between live readings and specified ranges of time. All data points, except for *Real Time*, are down sampled to 10 minutes when plotted on the Omega Link Cloud interface regardless of the Cloud subscription level. All Real Time data fully remains in the Historian. See section *6.2 Historian* for more information.

🚱 Omega Link				ADEVICES SHISTORIAN CSYSTEM
0101143F2DE86F22  0 0101143F2DE86F22 Main FW: 1.15.1.0 RF FW: Last reading: 4/19/2021, 841:17 PM	Temperature1 <sup>D1</sup> 26.4 <sup>+</sup> C	Temperature2 <sup>02</sup> 24.6-c		
e Home	1	Measurements	Alarm & Events	Ö Settings
Real Time Today This Week Custom	C Temperature1	E	Тетро	erature2
2- д. 	anotaes entites .	m	24 - 13 - 13 - 14 - 10 -	austreus austreus austreus austreus austreus

Figure 31: Omega Link Cloud sensor measurements – Graph View

#### 8.1.3.2 Alarms and Events

The Alarms and Events tab displays all alarms and events that were triggered by this device. Each alarm and event include a short message describing the nature of the alarm or event.

Marm Event Dism								
		Docur: 20:55:23						
		•						
	4/19 20:55-23	4/1920:55:23	4/19 20:55:23	4/19 20:55:23	4/19 20:55-23	4/19 20 55:23	4/19 20:55:23	4/192
	4/19 20:55:23	<del>งเชณฑ</del> าม Mess		4/19 20-59-23	4/1928:55:23	411926:523	419383933 Severity :	4/19
6:55:23 Time : 4/19/2021, 8:55:23 PM	eria 56:52	Mess			4/1938:35	419389533		4/19
Time :	41938553	Mess	sage :	6.30 is out of range (2.00, 2.00)	411938533	errsb3533	Severity :	

Figure 32: Omega Link Cloud Alarms and Events interface

#### 8.1.3.3 Settings (Define Alarms and Events)

The Settings tab allows users to change all settings relevant to how the device interacts with the Omega Link Cloud. Users can customize the device name, alarm/event thresholds, and sensor reporting properties.

To set a local alarm output once you are in the **Settings** tab, define the parameters of the alarm by defining the threshold. Your alarm can be configured to trigger when readings go **Above**, **Below**, or **Out of Range** of your defined threshold. Once you have defined your alarm parameters, click **Update** to finalize your changes.

Test Cataviau			
Test Gateway			
Alarm Settings			
Temperature1		Temperature2	
Out of Range	~	Out of Range	~
Threshold High		Threshold High	
Threshold Low		Threshold Low	
2		2	
Sensor Properties			
Reporting Interval (sec)		DeadBand	
20		5	

Figure 33: Omega Link Cloud Settings

### 8.1.3.4 What is Deadband in Settings?

It is standard to establish the desired threshold or setpoint to trigger an alarm when a condition is met. Triggering an alarm repeatedly in a short period, however, can produce unwanted results, such as having the alarm flip between inactive and active several times and triggering unwanted actions tied to that alarm as a result. Additionally, the constant alarm email notifications may result in an email service shut down.

To solve the alarm chattering issue, Omega has implemented a Deadband feature into the Omega Link Cloud. Also known as hysteresis, the deadband establishes a range, or threshold, of values from the setpoint that the Omega Link Cloud will accept before the alarm is triggered. The deadband threshold can either be defined as an absolute value or as a percentage of the setpoint value.






Figure 34: Setpoint as a percentage




Figure 35: Setpoint as an absolute value

In the Omega Link Cloud, the deadband feature in the alarm settings is expressed as a percentage. For example, if a user enters a value of 5 in the deadband text box, a range of +5% to -5% from the threshold has been established and the alarm will not be triggered within that region.

In OEG, the deadband feature in the alarm settings is expressed as an absolute value. For example, if a user enters a value of 5 in the Deadband text box, a range of +5 to -5 from the threshold has been established and the alarm will not be triggered within that region.

#### 8.2 Historian

The Historian tab allows users to create reports of past readings within a range of time and presents them as a graph. Through the Historian tab, users can export their chart data as a .csv file. Begin by clicking **Select Devices** and making your selection. Select the range of time your wish to view and choose a graph type from the selection. Your data will then be displayed and ready for export.



Figure 36: Omega Link Cloud Historian interface

#### 8.2.1 How to Generate a Historical Data Report

The Historian tab allows users to create reports of past readings within a range of time and presents them as a graph. Through the Historian tab, users can export their chart data as a .csv file. Begin by clicking **Select Devices** and making your selection. Select the range of time your wish to view and choose a graph type from the selection. Your data will then be displayed and ready for export.

Users can begin to generate a *Historical Data Report* by clicking the *Select Devices* button.



Figure 37: Historical Data Report parameters

Users can then select the desired device(s) to add to the report by clicking the associated checkboxes. Click **OK** to finalize the selection.



Selec	t Devices			
how	10 v entries		Search:	
2	Gateway Name	Device Name	* Device ID	🕈 Gateway ID 🕈
	omgw7ycqjq	00124B001E1E92CA	00124B001E1E92CA	omgw7ycqjq
	omgw7ycqjq	010115302FD10034	010115302FD10034	omgw7ycqjq
	omgw7ycqjq	010143312DE86F22	010143312DE86F22	omgw7ycqjq

Figure 38: Historical Data Report Select Devices interface

#### Select a period or a range of dates

To specify the range of time the report will cover, users can select **Today**, **This Week**, or **Custom** date and time. Click **Apply** to finalize the changes.

ustom	11	/01	12:0	0 AM	-11	/08	11:59	PM	1					
Time	<		Fe	eb 20	22					м	ar 20	22		>
	Su	Мо	Tu	We	Th	Fr	Sa	Su	Мо	Tu	We	Th	Fr	Sa
11/04/	30	31	1	2	3	4	5	27	28	1	2	3	4	5
05:29	6	7	8	9	10	11	12	6	7	8	9	10	11	12
11/05/	13	14	15	16	17	18	19	13	14	15	16	17	18	19
05:29	20	21	22	23	24	25	26	20	21	22	23	24	25	26
a constraint	27	28	1	2	3	4	5	27	28	29	30	31	1	2
11/06/ 05:29	6	7	8	9	10	11	12	3	4	5	6	7	8	9
11/06/		12	~	: 00	•	AM	~				: 59			
19:45				11	01 1	2.00	AM - 1	11/08 1	1.50	PM	<b>C</b> -	ncel		ppl

Figure 39: Custom date range calendar interface

#### Save the Result/Export Chart Data

Users can save and export the generated data by clicking the save icon **Control**. A .csv file of the data will be generated and the user will be prompted to download the file.



#### **Graph Data Presentation**

The Historian interface provides three methods of presenting graphed data: Plot Time Series, Plot Histogram, and Plot Prediction.




Figure 40: Graph data viewing options

#### **Plot Time Series**



Figure 41: Plot time series graph view

#### Plot Histogram



#### Figure 42: Plot Histogram graph view



#### **Plot Prediction**

To utilize the *Plot Prediction* feature, enter the date and time of the value you would like to predict and click the *Predict Future Values* button to display the data.



Figure 43: Plot Prediction graph view



#### 8.3 System Settings

The System settings for the Omega Link Cloud allow you to customize your profile information, the units of measure displayed, user access permission, subscription management, and includes contact information for technical support and feedback.

#### 8.3.1 Profile

The Profile tab allows users to configure settings such as associated email addresses, passwords, security questions, and notifications.

Using the email address associated with the account or by providing an SMS email address, users can receive notifications directly whenever an alarm or event is triggered.

Passwords can be updated by entering the old password in the text box then entering and confirming the new password as directed on the webpage. Security questions can be configured at the bottom of the Profile webpage.

mail:	Name:	SMS Email:	
		Click Add button to create/edit	Add
Time Zone:			
America/Los_Angeles	Ý		
Notification			
🛛 Alarm	e Event		
Change Password			
Old Password			
Old Password			

Figure 44: Omega Link Cloud Profile settings

#### 8.3.2 Units

The units tab allows users to set their preferred units of measure as they appear on the Omega Link Cloud. Changing the units here does not change the units of your sensing devices. It only changes the unit of measure as it appears on the Omega Link Cloud.

Weight		Pressure		Barometer		Temperature		Flow		Humidity	
kg	~	Pa	~	Ра	~	C	~	L/min	~	%RH	Ŷ
Voltage		Current		Illuminance		Resistance		Time		Frequency	
mV	~	mA	~	lx	~	ohm	~	S	~	Hz	~
Length		Volume		Velocity		DutyCycle		HeatFlux		DigitalInput	
m	~	L	*	m/s	~	%	*	W/m2	~	DIN	~
Gas		Magnetomete	<u>؛</u> ۲	Tilt		Acceleromete	ers				
ppm	~	gauss	~	deg	~	m/s2	~				

Figure 45: Omega Link Cloud local display units

#### 8.3.3 Users

The Users tab allows you to give others access to view the data for your gateway on their Omega Link Cloud accounts. To add a user, enter their email address in the text box and choose **Can Change** or **Can View** to grant full access or restrict access, respectively.

User Email			
Enter user email	Can Change		

Figure 46: Omega Link Cloud Add or Remove user access

### 8.3.3.1 How to Add Users

To add users to your Omega Link Cloud account, follow these steps:

					⊖ DE	VICES SHISTORIAN SYSTEM
	Units			ter Users		O Contact Us
Add User 🧿						
User Email			Existing Users			
	Can Change		Email	Rights :	Password	
Note: Can Change option allows u only allows user to view assigned	ser to update settings for assigned	devices. Can View option				
only allows user to their assigned	Derices.		Test1@omega.com	Can Change	Reset	
			Test2@omega.com	Can Change	Reset	
			Test3@omega.com	Can Change	Reset	
			Test4@omega.com	Can Change	Reset	

Figure 47: Omega Link Cloud Users tab

**Step 1:** On the Omega Link Cloud homepage, click on the **SYSTEM** tab, and click on **Users**. Enter the email address of the user you want to add.



- Step 2: Click the dropdown next to the email address text box and select the level of access the new user will have: Can Change or Can View.
- Step 3: Click the 📑 icon to add the user. The email address of the new user will appear on the Existing Users table.
- Step 4: Once the previous steps are complete, the new user will receive an email prompting them to register an Omega Link Cloud account. If no email is received within 10 minutes, the email may be in the user's spam folder.

#### 8.3.4 Subscription

The Subscription tab shows your current subscription tier and provides a link to the Omega website should you choose to upgrade your subscription plan. If you purchased the subscription with a billing email different than your Omega Link Cloud account email, you may link the two here.

#### 8.3.5 **Contact Us**

The Contact Us tab provides an email address link for direct engineering technical support. It also provides a text field for user feedback and comments.



Note: Note: Changing the units of measurement only affects the readings displayed on the Omega Link Cloud. Omega Link sensing devices interpret data in SI.



#### 8.4 How to Remove a Paired Smart Sensor from a Gateway

To remove a paired Smart Sensor (such as the SS-001) from a Gateway, follow the steps below:

- **Step 1:** Log in to the Omega Link Cloud account associated with the paired devices.
- Step 2: From the Omega Link Cloud device readings page, identify the Smart Sensor that will be removed, and click the Trash Can icon

S All Other D	evices 🕥	Test	88	
00124B002	1801			<b>e</b>
Temperature <b>24</b> •c	Humidity 50.5 <sub>%RH</sub>		Contact 2 <b>n</b>	

#### 8.4.1 How to Move a Paired Smart Sensor to a Different Gateway

To move a paired Smart Sensor (such as the SS-001) to a different Gateway, follow the steps below:

- Note: When moving a paired Smart Sensor to a different Gateway, alarm and event thresholds may be triggered and notifications based on user preference may be delivered. Notifications sent as a result of the re-pairing process may be disregarded.
  - **Step 1**: Navigate to the Omega Link Cloud Portal that is associated with the Smart Sensor and remove the Smart Sensor from the account.
  - **Step 2**: Ensure the unit is being powered with either a USB connection or batteries. Press and hold the Pairing Button on their Smart Sensor for 8 seconds so that the LED Status Indicator blinks red to factory reset the device, then release the pairing button.
- Note: The Pairing Button for the SS-001-RUG is in a pinhole on the underside of the device. Use a paperclip to press and hold the pairing button for 8 seconds so that the LED Status Indicator blinks red to factory reset the device, then release the pairing button.

After the factory reset, the LED Status Indicator on the Smart Sensor will turn Amber/Orange indicating the device is in pairing mode and is ready to be paired to a new Gateway.

Figure 48: Omega Link Cloud UI Smart Sensor readings



## 9 Certification

Safety:	EN 61010-1:2010
EMC:	EN 301 489-1 V2.2.0
	EN 301 489-3 V2.1.1
Radio:	EN 300 320-1 V3.1.1
	EN 300 220-2 V3.1.1

## **10 General Public License Statement**

This product contains software that is subject to an open-source license agreement including GNU General Public License ("GPL") or GNU Lesser General Public License ("LGPL"). With respect to the free/open-source terms, customers of this product have rights to acquire, modify and redistribute the source code in accordance of the terms of the GPL and LGPL. If you have any questions or wish to receive a copy of any source code that you may be entitled under the term, please contact us at:

#### iiot-opensource@omega.com

Please include the SKU of this product in your request. The subject should be: **GW001 GPL license statement request** The original source code is available on the corresponding hosting website.

GNU General Public License: https://www.gnu.org/licenses/gpl-3.0.en.html

GNU Lesser General Public License: https://www.gnu.org/licenses/lgpl-3.0.en.html

## **11 Specifications**

### Wireless Communication

Frequency\*: 915 MHz (-NA)

868 MHz (-EU)

#### Range\*\*: 1.2 km or up to 3.2 km for -NA models

\*Wireless communication is only available on qualifying variants

\*\*Maximum range possible when Smart Sensor is powered by USB and without obstruction

#### Power

AC Adapter: DC 12 V @ 2A

#### Interface\*

RJ45: 2x port USB: 2x USB 2.0 DC Jack: DC 12V power input Serial Port: RS232/RS485 Alarm: SSR 36 V DC 100 mA Antenna: 1x Antenna for Sub-1G (on qualifying models) \*Available interfaces vary by model of Gateway

#### Environmental

Rating: IP40

Operating Temperature: -20°C to 65°C (-4°F to 149°F,) non-condensing

#### Mechanical

Dimensions: 170 mm L x 100 mm W x 42 mm H (6.69" x 3.93" x 1.65")

#### Certifications

Contains FCC ID: WR3-MOD16370915

Contains IC ID: 8205A-MOD16370915

#### Emission & Immunity for EMI/EMS

FCC: FCC Part 15B

CE: Radio Equipment Directive 2014/53/EU, EMC Directive 2014/30/EU, RoHS Directive EU 2015/863

UKCA: Radio Equipment Regulations 2017, Electromagnetic Compatibility Regulations 2016, RoHS Regulations 2012

#### Radio Frequency & Human Exposure/SAR

FCC: FCC Part 15C (15.247) FCC MPE

#### Safety

*LVD:* EN 62368-1

#### General

Max number of Smart Sensors: Up to 40 Smart Sensors can connect to the Gateway unit.

All specifications are subject to changes without prior notifications. Please visit Omega.com for the latest information.

## WARRANTY/DISCLAIMER

OMEGA ENGINEERING, INC. warrants this unit to be free of defects in materials and workmanship for a period of **13 months** from date of purchase. OMEGA's WARRANTY adds an additional one (1) month grace period to the normal **one (1) year product warranty** to cover handling and shipping time. This ensures that OMEGA's customers receive maximum coverage on each product.

If the unit malfunctions, it must be returned to the factory for evaluation. OMEGA's Customer Service Department will issue an Authorized Return (AR) number immediately upon phone or written request. Upon examination by OMEGA, if the unit is found to be defective, it will be repaired or replaced at no charge. OMEGA's WARRANTY does not apply to defects resulting from any action of the purchaser, including but not limited to mishandling, improper interfacing, operation outside of design limits, improper repair, or unauthorized modification. This WARRANTY is VOID if the unit shows evidence of having been tampered with or shows evidence of having been damaged as a result of excessive corrosion; or current, heat, moisture or vibration; improper specification; misapplication; misuse or other operating conditions outside of OMEGA's control. Components in which wear is not warranted, include but are not limited to contact points, fuses, and triacs.

OMEGA is pleased to offer suggestions on the use of its various products. However, OMEGA neither assumes responsibility for any omissions or errors nor assumes liability for any damages that result from the use of its products in accordance with information provided by OMEGA, either verbal or written. OMEGA warrants only that the parts manufactured by the company will be as specified and free of defects. OMEGA MAKES NO OTHER WARRANTIES OR REPRESENTATIONS OF ANY KIND WHATSOEVER, EXPRESSED OR IMPLIED, EXCEPT THAT OF TITLE, AND ALL IMPLIED WARRANTIES INCLUDING ANY WARRANTY OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE ARE HEREBY DISCLAIMED. LIMITATION OF LIABILITY: The remedies of purchaser set forth herein are exclusive, and the total liability of OMEGA with respect to this order, whether based on contract, warranty, negligence, indemnification, strict liability or otherwise, shall not exceed the purchase price of the component upon which liability is based. In no event shall OMEGA be liable for consequential, incidental or special damages.

CONDITIONS: Equipment sold by OMEGA is not intended to be used, nor shall it be used: (1) as a "Basic Component" under 10 CFR 21 (NRC), used in or with any nuclear installation or activity; or (2) in medical applications or used on humans. Should any Product(s) be used in or with any nuclear installation or activity, medical application, used on humans, or misused in any way, OMEGA assumes no responsibility as set forth in our basic WARRANTY/DISCLAIMER language, and, additionally, purchaser will indemnify OMEGA and hold OMEGA harmless from any liability or damage whatsoever arising out of the use of the Product(s) in such a manner.

## **RETURN REQUESTS/INQUIRIES**

Direct all warranty and repair requests/inquiries to the OMEGA Customer Service Department. BEFORE RETURNING ANY PRODUCT(S) TO OMEGA, PURCHASER MUST OBTAIN AN AUTHORIZED RETURN (AR) NUMBER FROM OMEGA'S CUSTOMER SERVICE DEPARTMENT (IN ORDER TO AVOID PROCESSING DELAYS). The assigned AR number should then be marked on the outside of the return package and on any correspondence.

The purchaser is responsible for shipping charges, freight, insurance and proper packaging to prevent breakage in transit.

# FOR **WARRANTY** RETURNS, please have the following information available BEFORE contacting OMEGA:

- 1. Purchase Order number under which the product was PURCHASED,
- 2. Model and serial number of the product under warranty, and
- 3. Repair instructions and/or specific problems relative to the product.

FOR **NON-WARRANTY** REPAIRS, consult OMEGA for current repair charges. Have the following information available BEFORE contacting OMEGA:

- 1. Purchase Order number to cover the COST of the repair,
- 2. Model and serial number of the product, and
- 3. Repair instructions and/or specific problems relative to the product.

OMEGA's policy is to make running changes, not model changes, whenever an improvement is possible. This affords our customers the latest in technology and engineering.

OMEGA is a trademark of OMEGA ENGINEERING, INC.

© Copyright 2019 OMEGA ENGINEERING, INC. All rights reserved. This document may not be copied, photocopied, reproduced, translated, or reduced to any electronic medium or machine-readable form, in whole or in part, without the prior written consent of OMEGA ENGINEERING, INC.

## Where Do I Find Everything I Need for Process Measurement and Control? OMEGA...Of Course! Shop online at omega.com

## TEMPERATURE

- Thermocouple, RTD & Thermistor Probes, Connectors, Panels & Assemblies
- Wire: Thermocouple, RTD & Thermistor
- Calibrators & Ice Point References
- Recorders, Controllers & Process Monitors
- Infrared Pyrometers

## PRESSURE, STRAIN AND FORCE

- Transducers & Strain Gages
- Load Cells & Pressure Gages
- Displacement Transducers
- Instrumentation & Accessories

## **FLOW/LEVEL**

- Rotameters, Gas Mass Flowmeters & Flow Computers
- Air Velocity Indicators
- Turbine/Paddlewheel Systems
- Totalizers & Batch Controllers

## pH/CONDUCTIVITY

- PH Electrodes, Testers & Accessories
- Benchtop/Laboratory Meters
- Controllers, Calibrators, Simulators & Pumps
- Industrial pH & Conductivity Equipment

## DATA ACQUISITION

- Communications-Based Acquisition Systems
- Data Logging Systems
- Wireless Sensors, Transmitters, & Receivers
- Signal Conditioners
- Data Acquisition Software

## HEATERS

- Heating Cable
- Cartridge & Strip Heaters
- Immersion & Band Heaters
- Flexible Heaters
- Laboratory Heaters

## ENVIRONMENTAL MONITORING AND CONTROL

- Metering & Control Instrumentation
- Refractometers
- Pumps & Tubing
- Air, Soil & Water Monitors
- Industrial Water & Wastewater Treatment
- PH, Conductivity & Dissolved Oxygen Instruments